

**SPECIAL NOTES**

1. High Density Polyethylene (HDPE) corrugated pipe with internally formed smooth interior wall, ADS N-12 or approved equal, may be substituted for reinforced concrete pipe in paved and non-paved areas. This includes applications inside the right-of-way.
2. HDPE pipe joints shall be made using watertight couplers with “O”-ring gasket, ADS WT or approved equal, where rubber “O”-ring gasket (ASTM C-361) pipe is required on the plans. All other pipe shall have a bell and spigot joint with rubber gasket meeting ASTM F477.
3. Green warning tape 6” wide, marked “Caution Sewer Line Buried Below” shall be placed on top of the bedding material for the entire length of pipe.
4. Bedding shall be per Columbus Standard Drawing AA-S149.
5. Backfill within the right-of-way shall be Item 911 or Item 912 per City of Hilliard General Notes 34 & 35.
6. Backfill outside the right-of-way shall be Item 911 per City of Hilliard General Note 35 and per Columbus Item 901.04.
7. All HDPE pipe shall be mandrel tested per Columbus Item 901.21.