HILLIARD CODE FIXTURE REPLACEMENT SCHEDULE										
EXISTING FIXTURE						NEW FIXTURE				
MANUFACTURER	MODEL	DIST	LAMP	WATTS	HEIGHT	MANUFACTURER	MODEL	DIST	LAMP	WATTS
KIM	SHOEBOX	3	HPS	250	30'	GENERAL ELECTRIC	EANA5F45401BCDKBZ	4	LED	148
GENERAL ELECTRIC	GE M-400R2	3	HPS	200 OR 250	30'					
ARCHITECTURAL AREA LIGHTING	PROV-V3	3	HPS	150	14'	ARCHITECTURAL AREA LIGHTING	PROV-T3-32LED-4K-700	3	LED	76
ARCHITECTURAL AREA LIGHTING	PROV-H3	3	HPS	150	12.5'					
HADCO	VS15AB3YUE	3	HPS	150	12.5'	HADCO	VX15148AC3RNA3NSL	3	LED	70

APPROVED

Clyde R. Seidle 9-1-15

CITY ENGINEER DATE

SCALE: NONE

RETROFIT OF EXISTING LIGHTING

CITY OF

HILLIARD, OHIO

STANDARD CONSTRUCTION DRAWING

1/1

SL-19